



Water Environment Research Foundation
Collaboration. Innovation. Results.

Conveyance Systems

**FINAL
REPORT**

FOG Interceptor Design and Operation (FOGIDO) Guidance Manual

(Supplemental Report to 03-CTS-16T)

Co-published by



03-CTS-16TB

FOG INTERCEPTOR DESIGN AND OPERATION (FOGIDO) GUIDANCE MANUAL

Supplemental Report to 03-CTS-16T

by:

Joel J. Ducoste

North Carolina State University

Kevin M. Keener

Purdue University

John W. Groninger

Southern Illinois University

Leon M. Holt

Town of Cary

2008



The Water Environment Research Foundation, a not-for-profit organization, funds and manages water quality research for its subscribers through a diverse public-private partnership between municipal utilities, corporations, academia, industry, and the federal government. WERF subscribers include municipal and regional water and wastewater utilities, industrial corporations, environmental engineering firms, and others that share a commitment to cost-effective water quality solutions. WERF is dedicated to advancing science and technology addressing water quality issues as they impact water resources, the atmosphere, the lands, and quality of life.

For more information, contact:
Water Environment Research Foundation
635 Slaters Lane, Suite 300
Alexandria, VA 22314-1177
Tel: (703) 684-2470
Fax: (703) 299-0742
www.werf.org
werf@werf.org

This report was co-published by the following organization. For non-subscriber sales information, contact:

IWA Publishing
Alliance House, 12 Caxton Street
London SW1H 0QS, United Kingdom
Tel: +44 (0) 20 7654 5500
Fax: +44 (0) 20 7654 5555
www.iwapublishing.com
publications@iwap.co.uk

© Copyright 2008 by the Water Environment Research Foundation. All rights reserved. Permission to copy must be obtained from the Water Environment Research Foundation.
Library of Congress Catalog Card Number: 2008934929
Printed in the United States of America
IWAP ISBN: 978-1-84339-527-0/1-84339-527-4

This report was prepared by the organization(s) named below as an account of work sponsored by the Water Environment Research Foundation (WERF). Neither WERF, members of WERF, the organization(s) named below, nor any person acting on their behalf: (a) makes any warranty, express or implied, with respect to the use of any information, apparatus, method, or process disclosed in this report or that such use may not infringe on privately owned rights; or (b) assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, method, or process disclosed in this report.

North Carolina State University

This document was reviewed by a panel of independent experts selected by WERF. Mention of trade names or commercial products does not constitute WERF nor endorsement or recommendations for use. Similarly, omission of products or trade names indicates nothing concerning WERF's positions regarding product effectiveness or applicability.

ACKNOWLEDGMENTS

The authors of this report are indebted to the following water utilities, companies, and individuals for their cooperation and participation in this project:

- ◆ Town of Cary, North Carolina
- ◆ Oxford Tobacco Research Station, North Carolina
- ◆ Carolina Classic Manufacturing, Inc.
- ◆ Wilkes Enterprise, Inc
- ◆ Duke Roots, Inc.
- ◆ RootX Root Control Corp
- ◆ Solutions-IES

Research performed at North Carolina State University could not have been accomplished without the help of students and lab technicians. Tarek Aziz, a Ph.D. candidate at the time of this research, was responsible for a significant portion of the lab work. The principal investigators (PIs) would also like to thank Barbara Oslund and Heather Markell from Solutions-IES for the development, administration, and analysis of the FOG and roots survey.

The root study research carried out at Oxford Tobacco Research Station could not have been possible without the help of students and laboratory staff. Students that have worked to setup the roots control pilot system include Colleen Bowker, Liz Dinatale, Ojochide Idichaba, Akinawale Omofoye, and Justin Woods. The PIs are indebted to Dennis Metcalf from North Carolina State University, and Fred Smith and his team at the Oxford Tobacco Research Station, for the construction of the pilot system and maintaining the green house for proper tree growth. The PIs would also like to thank Donald Smith from the Town of Cary in the development of the grease interceptor design Microsoft Excel[®] spreadsheet.

The principal investigators would like to thank Mike Hogan and Duke Roots Inc. for the treatment chemicals and for sending a treatment team to apply their product to the roots at the pilot system. Many thanks to also Pat Monaghan of RootX Root Control Corp. for donating their chemical treatment product for the root control study in this research project.

Report Preparation

Principal Investigators:

Joel J. Ducoste, Ph.D., *North Carolina State University*

Kevin M. Keener, Ph.D., *Purdue University*

John W. Groninger, Ph.D., *Southern Illinois University*

Project Subcommittee

Mary Lappin, P.E. RC Liaison, *Kansas City Water Services Department*

Mark Kawamoto, P.E. PSC Chair, *Orange County Sanitation District*

Philip Friess, *County Sanitation Districts of Los Angeles County*

Gayle Tupper, *East Bay Municipal Utility District*

Kevin Sherman, *Florida Onsite Wastewater Association*
Hugh T. Garrison, *Metro Water Services, Nashville*
Charles Vanderlyn, PE, *U.S. EPA*

Steering Subcommittee

Frank Brockman, *Cobb County*
Ben Horenstien, *East Bay Municipal Utilities District*
Mike Dunbar, *South Coast Water District*
John Redner, PE, *County Sanitation Districts of Los Angeles County*
Jim Peters, PE, DEE, *Florida Water Environment Association Utility Council*
Quyen Tram, PE, *Toho Water Authority*
Brian Wheeler, *Toho Water Authority*
Nick Arhontes, PE *Orange County Sanitation District*
Terrie Mitchell, *Sacramento Regional County Sanitation District*
Drew Mihocko, *City of Philadelphia Water Department*
Tim McKim, PE, *Reedy Creek Energy Services*
Adel Hagekhalil, *City of Los Angeles*
Christine Mikulice, *County of San Francisco Water Pollution Control*
Gail Chester, Ph.D., PE, *Central Contra Costa Sanitary District*
Brett Goodman, *Gainesville Regional Utility*
Rick Oliver, *Jensen Precast*

Water Environment Research Foundation

Director of Research	Daniel M. Woltering, Ph.D.
Senior Program Director:	Amit Pramanik, Ph.D., BCEEM
Program Director:	Lauren Fillmore
Program Manager:	Jane Casteline

ABSTRACT AND BENEFITS

Abstract:

Fat, oil, and grease (FOG) is generated every day by food preparation and cleaning activities conducted at commercial establishments and, on a smaller scale, by residential sewer usage. FOG accumulations in the sanitary sewer collection system result in reduced capacity that may lead to sanitary sewer overflows (SSO) if not periodically cleaned. As the accumulation commences, the effect of slowed wastewater flow exacerbates the rate of accumulation and deposit of FOG materials onto the pipe walls, thereby reducing capacity.

The primary means of controlling FOG blockages is to capture and retain FOG materials through passive grease interception devices. Limited scientific studies have evaluated these devices. Many claims of enhanced performance made by manufacturers of grease and oil interception devices need to be verified by objective and unbiased research protocols. A companion report, *Assessment of Grease Interceptor Performance*, has conducted such a study. The FOGIDO report outlines the recommendation for the sizing and configuration of grease interceptors (GI) using research information from the companion report. In addition, a Microsoft Excel[®] spreadsheet GI size calculator has been developed to compute flows and FOG loading to size the GI for a specific food service establishment.

Benefits:

- ◆ Provides an alternative approach for sizing GIs for food service establishments.
- ◆ Improves process performance of GIs, with a higher percent grease removal, based on alternative design configurations.
- ◆ Provides more efficient sizing of GIs.
- ◆ Provides more transparency in computation of GI sizing.

Keywords: Fats, oils, grease, FOG, grease interceptor design, GI, SSO, FSE, food service establishment.

TABLE OF CONTENTS

Acknowledgements.....	iii
Abstract and Benefits.....	v
List of Tables.....	vii
List of Figures.....	viii
Executive Summary.....	ES-1
1.0 Introduction.....	1-1
1.1 Background.....	1-1
2.0 Design Methodology for Grease Interceptors.....	2-1
2.1 Inlet/Outlet GI Configurations.....	2-1
2.2 Baffle Wall Configurations.....	2-2
3.0 Grease Interceptor Sizing Considerations.....	3-1
3.1 Premise.....	3-1
3.2 Grease Interceptor Sizing.....	3-13
4.0 Factors Effecting GI Performance.....	4-1
4.1 Impact of Emulsifiers on Grease Interceptor Performance.....	4-1
4.2 Impact of High Temperature Washwater on Grease Interceptor Performance....	4-2
4.3 The Role of Grease Interceptor Maintenance on Performance.....	4-2
5.0 Conclusions and Future Work.....	5-1
5.1 Conclusions.....	5-1
5.2 Future Work.....	5-1
References.....	R-1

LIST OF TABLES

1-1	IAMPO, UPC- Appendix H – Recommended Procedures for Design, Construction, and Installation of Commercial Kitchen Grease Interceptors (IAMPO, 2004)	1-1
1-2	UPC Table for Sizing of GI, IAMPO (2004).....	1-3
1-3	Gravity Grease Interceptor Sizing (IAMPO UPC 2006)	1-4
1-4	PDI Claims and Concerns Based on Design Procedure.....	1-5
1-5	NPCA Claims and Concerns Based on Design Procedure	1-6
3-1	Summary of FSE Fixtures.....	3-2
3-2	Summary of Calculations for Partially Filled Pipes Shown in Figure 3.1	3-4
3-3	Summary of Sample FSE for Calculation of Maximum Flow	3-7
3-4	Maximum Flow Rate Table	3-12

LIST OF FIGURES

2-1	Design of Distributed Plane Jet Grease interceptor	2-3
2-2	Flow Straightening Vanes of Distributed Plane Jet Grease Interceptor	2-4
2-3	Distributed Grease Interceptor	2-4
2-4	Short Inlet Grease Interceptor	2-5
2-5	Distributed Baffle Wall Design	2-5
2-6	Flared Baffle Configuration	2-6
3-1	Diagram of Partially Filled Pipe	3-3
3-2	Definition of Variables for calculation of Area and Wetted Perimeter of Partially Filled Pipes.....	3-4
3-3	Manning's Equation Flow vs. Fraction Filled	3-5
3-4	Graphic of Flow Contribution from Various Sink Fixtures.....	3-6
3-5	Contact information and FSE Input at the Top of the Spreadsheet	3-8
3-6	Data Input for Ware Washing Fixtures.....	3-8
3-7	Food Preparation Fixture Input Section	3-9
3-8	Summary of All Fixtures and Flow Contribution	3-11
3-9	Flow Data Collected Over Operational Ours at Full-Fare FSE	3-12

EXECUTIVE SUMMARY

Objectives:

- ◆ Describe the current state of understanding of gravity grease interceptor (GI) design and sizing and how it relates to the current experimental and computational research.
- ◆ Establish a new, transparent method for the calculation of flow rate into GIs.
- ◆ Develop a new equation for GI sizing, taking into consideration expected FOG and solids accumulation.
- ◆ Discuss potential factors that could decrease the FOG removal effectiveness of a gravity GI.

Current Situation

Several proposed equations exist in the literature for the sizing of grease interceptors. Typically, these equations lack transparency (i.e., very little background information is provided about their development) and may not take into account established knowledge of gravity separators. Often times, these interceptors are oversized, resulting in added cost to the food service establishment (FSE) owner as well as the negative impact associated with hydrogen sulfide production. The present research aims to utilize the extensive field, laboratory, and numerical observations of GI performance completed in a companion report to establish tools to design grease interceptors.

Grease Interceptor Configuration

The literature is full of opinions about grease interceptor design; most requiring compartmentalization and inlet and outlet tees near the GI bed without any scientific basis for the suggested design configuration. Field, experimental, and computational experience with such designs performed in this research study has enabled the research team to develop more effective configurations and make recommendations that have been shown to improve the FOG removal performance.

These design enhancements generally involve better distribution of the flow within the GIs to allow for quiescent conditions that enhance gravity separation. In addition, design suggestions for alternative inlet and outlet tees are based on extensive laboratory and pilot experimental tests, field observations, and numerical simulations. Simulation of these alternative designs indicated approximately 90% removal of influent fats, oil, and grease (FOG) in the free globule range (150 μm) with as little as 20 minutes hydraulic residence time.

Estimation of Food Service Establishment Flow and Sizing of Grease Interceptors

The current design methodology proposes that the design flow into a grease interceptor be derived from the maximum flow from the kitchen. In order to calculate this maximum flow,

the research team has developed a classification of kitchen fixtures that enables the user to assign an appropriate flow based on the fixture in use and in terms of typical flow rate units such as gallons per minute (gpm).

According to common kitchen practice, some kitchen sinks are drained from a filled state, while others are never drained and only experience the flow contribution from their associated faucet. The potential contribution of the filled sinks is determined through the use of Manning's Equation in conjunction with various plumbing characteristics. Faucet flow contributions are calculated based on known peak discharge limitations for the various fixtures in a kitchen.

Two methods are proposed for the use of these flow characterizations. The first, and preferred method, is a spreadsheet calculator where the various parameters is entered and the maximum flow is then determined for the specific food service establishment. The alternative method is a table built from the basic calculations embedded in the spreadsheet, with some assumptions that may not be consistent across all food service establishment kitchens. The tabular method should only be used if these assumptions are applicable for the specific food service establishment kitchen configuration.

After determining the calculation of the maximum flow rate, a 1/3 factor is proposed based on observation of field grease interceptor hydraulic operations. The modified flow rate then becomes the design flow for the grease interceptor. A sample calculation using the proposed approach in this study is provided. This calculation displays the maximum flow rate, the design flow rate, and collected field data that depicts the actual flow through the GI.

After establishing the GI design flow, the GI storage space is determined to account for the FOG and solids loading. The FOG and storage space is based not only on the FOG and solids loading into the GI but also the amount of FOG and solids removed by the GI, the sludge volume index of the solids, and the pump-out frequency.

Need for Future Research

The design methodology proposed in this study utilizes some assumptions related to the state of the FOG and solids entering the GI. However, these assumptions may not be consistent across all food service establishments. Future research needs to include a methodology to characterize the food service establishment waste stream. This detailed characterization would provide better guidance into the extent of FOG and solids that can be removed within the GI and possibly offer alternative recommendations into improving the GI removal. In addition, more GI field observations need to be performed across different types of food service establishments that have retrofitted the GI based on the recommendations in this report. This additional field data would validate the proposed design configurations and increase the much needed transparency in the entire GI design process.

CHAPTER 1.0

INTRODUCTION

1.1 Background

Researchers reviewed the literature regarding the design, operation and maintenance of grease interceptors (GIs). Discussed in this section are excerpts from three documents: 1) UPC guidelines (IAMPO, 2004); 2) a GI guide developed by the plumbing and drainage institute (PDI) (PDI, 1998); and 3) a design considerations document put together by the National Precast Concrete Association (NPCA) (NPCA, 2007). Though several of the points discussed by these documents are valid in the performance of GIs, they generally underestimate the complexity of FOG removal. All of these documents suggest some claims or assumptions that are now in question due to the results of this research (mentioned in the companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*). Below is an analysis of those documents. Table 1-1 provides a critique of the initial IAMPO 2004 GI design guidelines. An updated document is discussed in the following section.

Table 1-1. Recommended Procedures for Design, Construction, and Installation of Commercial Kitchen Grease Interceptors (IAMPO, 2003, Uniform Plumbing Code Appendix H).
Reprinted with the permission of the International Plumbing and Mechanical Officials

<p>H 103.1 Interceptors shall be constructed in accordance with the design approved by the Authority Having Jurisdiction and shall have a minimum of two compartments with fittings designed for grease retention.</p>	<p>According to laboratory and pilot scale GI tests, the use of two compartments has not generally lead to an improved GI performance (companion report, 03CTS16TA, <i>Assessment of Grease Interceptor Performance</i>). As shown in this companion report, the use of a mid-baffle wall seems to enhance only those GI designs with a distributed inlet/outlet configuration. With the traditional inlet designs, there is the possibility of short circuiting from the inlet pipe to the mid-baffle pipe. Conversely, with the distributive inlet configuration used in this study, the mid-baffle wall prevents the bypass of the central region of the reactor that would allow a large fraction of the inlet flow directly into the outlet pipe. In addition, the statement, "...fittings designed for grease retention." is unclear and would likely depend on the uniqueness of the GI design and whether it can enhance process performance.</p>
---	---

<p>H 106.1 Parameters. The parameters for sizing a grease interceptor for one or more fixtures are hydraulic loading and grease storage capacity.</p>	<p>As discussed in the companion report, 03CTS16TA, <i>Assessment of Grease Interceptor Performance</i>, the sizing of a grease interceptor is a complex function of residence time, initial FOG droplet size, and internal GI configuration. According to the 3D CFD simulation for one given hydraulic loading and the same influent oil concentration, a change in the inlet droplet size can result in a significant reduction in performance (i.e., from ~80% to 10% removal for the 150 and 80 micron size, respectively). The literature has also demonstrated the importance of inlet FOG condition on the removal effectiveness of a GI (Hee et al., 2006). The results of this study seem to suggest that the development of a universal GI design that can be sized solely on the hydraulic loading and the FOG storage capacity is too simplistic. It is possible that analysis of the FOG influent characteristics will have to be assessed prior to the selection of the most appropriate GI size and design.</p>
<p>H 106.2 Sizing Formula. The size of the interceptor shall be determined by using the method outlined in Table H-1.</p>	<p>Table H-1 (Table 1-2) attempts to quantify the size required of an interceptor as a result of the flow and cleaning demands for a given FSE. This table does not take into account: the characteristics of the influent FOG (i.e., temperature, oil droplet size, use of emulsifiers) or GI configuration, albeit, these parameters are difficult to include in a simple sizing relationship. The use of such formulas may oversize or undersize the GI needed to achieve at least 90% removal from the influent. Results from this study suggest that increasing the size of the GI will only provide nominal improvement in the percent removal for FOG droplet sizes of 150 microns (companion report, 03CTS16TA, <i>Assessment of Grease Interceptor Performance</i>). Further, the GI internal configuration, GI cleaning cycle, and temperature or buoyancy driven flows as seen with field measurements may significantly impact the removal efficiency (<i>Assessment of Grease Interceptor Performance</i>).</p>

IAMPO, UPC- 2006 – Revised Procedures for Design, Construction, and Installation of Commercial Kitchen Grease Interceptors

Recently, the UPC code was revised to change their grease interceptor design structure from Equation 1.1 and Table 1-2 to the use of drainage fixture units (DFU) (Table 1-3). DFUs are assigned to different fixtures and equipment that can potentially discharge FOG into the grease interceptor. The assigned DFUs for a given type of fixture or equipment are a function of whether it is used in a public or private setting or if it is part of an assembly (i.e., larger facilities). No explanation was provided into the derivation of these values albeit, they seem to be related to the maximum flow capacity for the specific equipment and connected pipe size. Food service establishment items that do not fall into one of the items are computed using a separate table. The final grease interceptor size is based on a 30 minute residence time. However, no information is provided on recommendations for alternative GI geometry configurations.

$$\text{Number of meals per peak hour} \times \text{Waste Flow Rate} \times \text{Retention Time} \times \text{Storage Factor} = \text{GI Size} \quad (1.1)$$

Table 1-2. UPC Table for Sizing of GI (IAMPO, 2004).

Reprinted with the permission of the International Plumbing and Mechanical Officials

Waste Flow Rate

a. With dishwasher	6 gallon (22.7 L) flow
b. Without Dishwasher	5 gallon (18.9 L) flow
c. Single Service Kitchen	2 gallon (7.6 L) flow
d. Food Waste disposer	1 gallon (3.8 L) flow

Retention Times

Commercial Kitchen Waste

Dishwasher 2.5 hours

Single Service Kitchen

Single Serving 1.5 hours

Storage Factors

Fully Equipped Commercial Kitchen 8 hours operation: 1
 16 hours operation: 2
 24 hour operation: 3

Single Service Kitchen 1.5

Table 1-3. Gravity Grease Interceptor Sizing (IAMPO UPC, 2006).
 Reprinted with the permission of the International Plumbing and Mechanical Officials

DFUs (1)	Interceptor Volume (2)
8	500
21 ⁽³⁾	750
35	1000
90 ⁽³⁾	1250
172	1500
216	2000
307 ⁽³⁾	2500
342	3000
428	4000
576	5000
720	7500
2112	10000
2640	15000

(1): The maximum allowable DFUs plumbed to the kitchen drain lines that will be connected to the grease interceptor

(2): This size is based on: DFUs, the pipe size from Nayar, 1992

(3): Based on 30 minute retention time

PDI – Guide to Grease Interceptors – Eliminating the Mystery (PDI, 1998)

The Plumbing and Drainage Institute (PDI) validates small in-kitchen grease interceptors through their own procedure (PDI-G101), which describes a method for quantifying the performance of a given interceptor. In general, this document describes the advantages of the small-scale interceptors and indicates the flaws and challenges of large scale interceptors. Although the PDI is attempting to create a standard for performance regarding FOG removal efficiency, several of the performance claims and concepts presented by the PDI document are also in question as a result of the present research. These claims and possible concerns are described in Table 1-4.

Table 1-4. PDI Claims and Concerns Based on Design Procedure.
Reprinted with the permission of the Plumbing and Drainage Institute

<p><u>FOG removal process (pg. 1, paragraph 5):</u> “To separate [FOG] from the FSE wastewater stream, an interceptor provides separation chambers, which allow FOG to rise to the surface. FOG free water then exits from the separation chamber at the low point farthest from the inlet end.”</p>	<p>The PDI document does not consider the characteristic of the influent FOG (i.e, droplet size, temperature, oil type) or mention the effluent discharge concentration that is considered to be FOG free. This research has revealed performance changes as a result of GI residence time (albeit, there seems to be a limiting size that does not produce significant % removal for 150 micron FOG globule diameter), internal GI configuration, and influent FOG characteristics.</p>
<p><u>The factors of FOG removal (pg. 1, paragraph 6):</u> “To simplify the influences which affect separation one could say there are only three major factors which must be considered. They are the design of the interceptor, the installation of the interceptor, and the maintenance of the interceptor.”</p>	<p>While this statement does seem consistent with part of the research study, it does leave out the influent conditions of the FOG (i.e., FOG globule size and stability and influent temperature). Once characterized, an appropriate design could be selected to achieve at least 90% removal assuming cleaning maintenance is performed in a timely manner.</p>
<p><u>The uses of baffles in a reactor (pg.3, paragraph 2):</u> “The baffles serve to lengthen the flow path of the effluent to increase the time of separation while providing a non-turbulent environment for separation to take place.”</p>	<p>Research indicates that certain baffle designs may result in high velocity zones that may transport FOG globules through the system and reduce the time for proper gravity separation. However, the present research has shown that the impact of the mid baffle wall will depend on the inlet/outlet configurations.</p>
<p><u>Maintenance of a PDI certified interceptor (pg. 8, paragraph 2):</u> “A PDI certified interceptor has a rated retention capacity equal to twice its flow rate expressed in pounds. For example, a 35 GPM interceptor is rated to retain at least 70 lbs of grease. A user may determine the cleaning schedule by determining how much grease has been trapped over a period of time.”</p>	<p>The claim suggests that, regardless of influent condition, the GI will remove FOG until this parameter (double the flow rating) is met. Again, this performance criterion does not address the influent condition since the performance of a GI does change with the influent FOG globule size (companion report, 03CTS16TA, <i>Assessment of Grease Interceptor Performance</i>).</p>
<p>Regarding the cleaning frequency and meeting code requirements of discharge < 100 ppm (pg. 8, paragraph</p>	<p>The claim suggests that the required discharge will be met within the required cleaning cycle. This claim is unrealistic as it does not incorporate the configuration of a given interceptor or the influent characteristics.</p>

NPCA - Design Considerations and Discussion of Large Outdoor Grease Interceptors (NPCA, 2007)

As a leading source of GI construction materials, the National Precast Concrete Association (NPCA) naturally has a vested interest in informing individuals about grease interceptors. Table 1-5 discusses several of the statements made in this document that are now in question as a result of the research performed to date.

Table 1-5. NPCA Claims and Concerns Based on Design Procedure (NPCA, 2007).

Reprinted with the permission of the National Precast Concrete Association

<p>(pg. 4, paragraph 3): “Actual wastewater usually contains various emulsifying chemicals, and the mixture is agitated before discharge to the trap or interceptor. While it would be impractical to evaluate all the variables that make up wastewater, it is important to remember that increasing the retention time (by increasing size) allows time for the FOG’s to separate.”</p>	<p>The results of this study suggest that retention time is an important parameter up to a certain value. However, beyond this value, the benefits of increasing the GI size are diminished (companion report, 03CTS16TA, <i>Assessment of Grease Interceptor Performance</i>). As the results have shown in this companion report, a tripling of the residence time only resulted in a 10% increase in FOG removal consisting of 150 micron FOG globule sizes. An additional factor that is also important is the composition of the influent. As documents citing the API oil-water gravity separators note, oil droplet sizes below 150 microns are no longer considered removable by gravity separation (Hee et al., 2006). A numerical simulation of FOG globules performed during this study confirmed that only 10% removal of 80 microns is expected simply from gravity separation (<i>Assessment of Grease Interceptor Performance</i>). In addition, the selection of the GI configuration for the same retention time can significantly impact the FOG removal efficiency. As shown in the companion report, the inclusion of the mid baffle wall improved the removal efficiency of the distributed inlet configuration while reduced the removal efficiency for the standard GI configuration. Hence a more comprehensive approach must be taken when sizing and selecting the GI for efficient FOG separation.</p>
<p>(pg. 4, paragraph 4): “Regulatory bodies set different effluent discharge limits all around the country. Presently there is no one recognized maximum allowable level of [Animal, Vegetable FOG] discharge, although the different values are relatively similar.”</p>	<p>Discharge regulation at this point is somewhat arbitrary as research is needed to understand the conditions that FOG deposits form in the sewer collection systems. This study was able to determine the basic constituents of a FOG deposit but did not determine their rate of formation and the conditions that influence their formation rate. In addition, current CFD simulations of the GI separation process indicate that GI removal performance may be independent of the influent FOG concentration. In this study, CFD simulations have reported 80% removal of the influent FOG concentration whether it was 1000 mg/L or 3000 mg/L. Preliminary experiments have confirmed these results and further suggest that standard interceptors may not be able to maintain discharge limits for high influent FOG concentrations.</p>

<p>Regarding Factors Effecting GI Sizing (pg. 5, paragraph 2, # 1-5). The document list 5 factors effecting sizing: 1. Retention Time, 2. Flow Rate, 3. Concentration, 4. Pumping Frequency, 5. Chemistry</p>	<p>This research has indicated performance changes as a result of: Retention time (which also incorporates #2 (Flow Rate)), and Chemistry. CFD simulations have shown a significant difference in percent removal due to influent globule size. The concept, however, that enough residence time will significantly improve the removal of any FOG globule size is somewhat unrealistic as shown in this study and in the literature (Hee et al, 2006) (i.e., below the free globule size (<150 micron), gravity separation will not provide significant removal). In addition there is a point of diminishing returns where increasing the size of the GI to achieve longer residence times does not significantly improve the FOG separation process.</p> <p>As stated previously, several CFD simulations performed with varying influent concentrations (#3) displayed no significant performance changes. This does, however, relate to point #4 that eventually a threshold will be reached in the FOG capacity.</p> <p>Point #4 also refers to the interceptor acting as a heat sink to cool the influent stream. The effect of a hot influent (relative to a cooler tank) has been investigated and shows that a buoyancy driven flow will occur that has the potential for scouring already separated FOG if carried out for an extended period.</p>
<p>(pg. 6, paragraph 2) Regarding the physical sizing of an Interceptor. This document goes into detail comparing municipalities' variation on the sizing of grease interceptors. The document performs calculations for commonly utilized GI sizing and compares the results (pg. 9).</p>	<p>The table indicates that for a given restaurant type, municipalities can vary as much as 400 gallons for smaller restaurants to 11,000 gallons for larger restaurant flows. Research indicates minor improvements (i.e. 10% increase in FOG removal) by tripling the residence time. Moreover, the benefits observed with more effective GI design configurations displayed even smaller percent improvements in performance with increasing residence time. Bottom line, residence time is only one of a complex array of factors that must be incorporated in a design strategy for effective removal of FOG from an FSE or high density residential complex.</p>

Currently, empirical formulas are utilized for sizing grease interceptors. In addition, manufacturer claims that a specific design will remove influent FOG are often taken at face value. Experimental tests and CFD simulations described in the companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*, have shown that FOG removal from the influent stream varies with GI design and influent characteristics (i.e., average droplet size, droplet distribution, and velocity distribution). The data in this research further suggests that a well designed GI will only remove so much FOG regardless of the influent concentration., representing a significant shift in the standard accepted practice for assessing FOG removal.

Standard practice is based on the precept that the FOG level in the GI effluent will depend on the influent concentration. Consequently, an effluent discharge limit of 100 ppm can only be achieved if the influent is not much higher than 1000 ppm, given 90% removal efficiency.

While the data collected in this study has primarily been performed with oils that are mono- or poly-unsaturated, it is likely that largely saturated FOG will not be significantly removed at higher percentages. In addition, there is an increasing usage of unsaturated FOG in restaurants due to the high concern that saturated FOG have on human health (Garza, 2005). Consequently, the results of the tests performed in this study may be more indicative of the type of FOG being discharged by current food service establishments.

While more sophisticated design changes could be made to the standard GI (i.e., addition of tube/plate settlers or non traditional baffle wall shapes), one must be careful about the potential impact of these design changes on the ease of cleaning the accumulated material within the GI. GI clean out is still an important part of the maintenance process as shown in field evaluations discussed in the companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*.

In this study, a few design configurations seemed to produce similar removal results ranging from 84-87% (based on the 20-minute residence time). These include the standard no-baffle configuration, distributive configuration, flared inlet/outlet, and the short inlet-standard outlet-no baffle configuration. Interceptors designed in these configurations may be expected to remove approximately 85% of non-emulsified or non-dispersed influent FOG (i.e., FOG greater than or equal to 150 microns globule size). Each of these design configurations are unique and not interchangeable due to the flow pattern that is produced. Moreover, these alternative designs allow for clean out maintenance that is currently performed by third party companies for the food service establishments (FSEs). Bottom-line, a pre-treatment strategy must include at minimum an optimized GI design (i.e., one of the suggested configurations in this chapter) to help reduce the FOG concentration using gravitational separation.

CHAPTER 2.0

DESIGN METHODOLOGY FOR GREASE INTERCEPTORS

Grease interceptors work to remove FOG and other materials primarily through gravity separation. Consequently, it is important to provide conditions that will allow FOG globules or solids to separate from the liquid stream with minimal disruption that may be caused by local fluid velocities. These local velocities can interact with the separated FOG or solids layer, cause breakup of FOG globules and reduce their terminal migration velocities, or cause reactor short circuiting and reduce the separation time necessary for efficient removal of FOG globules or food solids. Moreover, as mentioned earlier, the accumulation of FOG and solids ultimately means that the grease interceptor must be cleaned periodically. Hence, sophisticated grease interceptor designs that impact required cleanout maintenance cannot be encouraged. Therefore, the designs presented in this section are based on modifications that still provide ease of access and maintenance to grease interceptors.

2.1 Inlet/Outlet GI Configurations

Fluid velocities near the inlet and outlet should not exceed 0.015 m/s as results from experimental tests and numerical simulations revealed poorer separation performance at higher velocities. Local fluid velocities can be reduced by distributing the influent/effluent flow across a larger cross-sectional area. Ideally, the cross-sectional area would occupy the entire cross section of the of the grease interceptor (i.e., depth times height) as this setup would provide the lowest fluid velocities. A proposed design with this configuration would require a perforated baffle to distribute the influent flow. However, due to the potential for fast settling solids present in FSE waste streams, an additional compartment with a perforated baffle close to the inlet may cause significant deposition upstream from this baffle and reduce its effectiveness.

The current suggested design involves the distributed plane jet (DPJ) inlet/outlet described in the companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*. A detailed schematic with dimensions for the DPJ is provided in Figure 2-1. The dimensions have been normalized to coordinate implementation with any size rectangular grease interceptor. Important features in the DPJ design include straightening vanes to quickly distribute the local velocities within the expansion joint and the length of the rectangular portion (Figure 2-2). The straightening vanes are only used with the inlet version of the DPJ design.

An alternative to the DPJ design configuration is the distributed pipe configuration displayed in Figure 2-3. This design is considered easier to install and requires less space than the DPJ. As discussed in the companion report *Assessment of Grease Interceptor Performance*, the distributed pipe configuration in Figure 2-3 produces a circulation flow pattern that places higher local velocities near the grease interceptor wall and provides an upward motion in the central region that seems to enhance separation. When utilized with a mid-baffle wall, the results are better than the standard grease interceptor configuration.

A final alternative inlet/outlet design consists of utilizing a shorter standard inlet pipe with a standard outlet pipe configuration and no mid-baffle wall configuration (Figure 2-4). Results with this configuration produced comparable FOG removal performance with both the DPJ and the distributed inlet with mid-baffle wall results. As with the distributed inlet design, this shorter standard inlet pipe configuration is easier to install than the DPJ design but would require significant modifications to the overall GI configuration to remove the mid baffle wall.

2.2 Baffle Wall Configurations

This study demonstrated that grease interceptor designs should only include baffle walls with specific inlet/outlet configurations. Overall, the mid-baffle wall should be designed to distribute the flow and minimize the occurrence of high local fluid velocities. However, for simple retrofits of existing grease interceptors, the standard mid-baffle wall configuration could be used since field observations, experimental and numerical tests have revealed improved performance with simply changing the influent pipe configuration.

Two particular designs that have worked well are shown in Figures 2-5 and 2-6. These mid-baffle walls can be used with the DPJ and distributed influent configurations. The mid-baffle wall is still located in the same position as in the standard GI configuration since computer models did not reveal any enhanced performance with the relocation of the mid-baffle wall. However, as mentioned in the previous section, the mid-baffle wall should not be used if a shorter standard inlet pipe with a standard outlet pipe configuration is selected.




Figure 2-1. Design of Distributed Plane Jet Grease Interceptor.

H = Height of WSE

W = Internal Width of Tank

D = Pipe Diameter




Figure 2-2. Flow Straightening Vanes of Distributed Plane Jet Grease Interceptor.




Figure 2-3. Distributed Grease Interceptor.




Figure 2-4. Short Inlet Grease Interceptor.




Figure 2-5. Distributed Baffle Wall Design.




Figure 2-6. Flared Baffle Configuration.

CHAPTER 3.0

GREASE INTERCEPTOR SIZING CONSIDERATIONS

3.1 Premise

Several challenges arise in the sizing of grease interceptors. From the standpoint of the FSE owner, large interceptors require greater installation costs, higher maintenance costs, and run the risk of foul odors as a result of hydrogen-sulfide production. From the standpoint of municipalities, GIs must be sized to protect the operation of the sewer collection system. The fact that each FSE operates differently and have a wide variety of waste stream characteristics makes this a challenging task. It is, therefore, necessary to utilize defensible standards for the sizing of GIs.

The flow contribution of a FSE kitchen to a GI is based on the available plumbing fixtures utilized within the kitchen. The project team, in conjunction with the Town of Cary, North Carolina, characterized plumbing fixtures common to a FSE kitchen. Table 3-1 provides a description of common fixtures.

In Table 3-1, kitchen fixtures are divided into eight different groups. Observation of typical kitchen practices indicate that, based on the use of a fixture, the flow contribution from the sink can either be quantified by draining a filled sink or by direct faucet flow. In the case where the fixture does not drain from a filled sink, the flow contribution of the given fixture should be the maximum allowable faucet flow. This value is commonly regulated for a given pressure (1992 Energy Act). When the kitchen fixture practice dictates that the sink will drain from a filled state, a more appropriate alternative of quantifying the flow to the GI would be to use Manning's Equation in comparison with the volume of the sink to determine the peak allowable flow.

Table 3-1. Summary of FSE Fixtures.

Fixtures	Description	Flow Contribution
Ware Washing Fixtures	Fixtures in which kitchen pots, pans, and other kitchen utensils are washed. These fixtures often feature three compartments where the dishware is washed. After each cleaning process the three sinks are then drained.	Manning's Equation
Food Preparation Fixtures	Food preparation fixtures are sink fixtures primarily involved in the preparation of meats, vegetables, and seafood. Flow rate contributions from these fixtures are calculated based on the primary activity of cleaning and de-thawing food by means of running water from the faucet.	Faucet Flow
Pre-Rinse Fixtures	Pre-rinse fixtures include those sinks involved in the rinsing of ware prior to washing. Flow rate contributions from these fixtures are calculated based on the primary activity of rinsing ware by means of water flow through a spray nozzle. Note: If a pre-rinse spray nozzle is associated with a sink that has a combination faucet and spray nozzle, a discharge flow rate should be entered for the pre-rinse fixture and the ware washing or prep sink faucet fixture.	Faucet Flow
Dishwasher Units	<p>The dishwasher units are devices used in the automated washing of ware. Dishwasher units include, but are not limited to rack type, under counter, conveyor, and plate washing machines. Flow rates from these units are determined by manufactures specifications on peak wastewater discharges.</p> <p>Clothes washers used for the cleaning of soiled clothes, linens, and towels associated with food service establishments operation shall be entered as a dishwasher unit.</p>	Discharge Flow
Cooking Equipment	Cooking equipment fixtures are those apparatuses that have a connection to the plumbing system for the disposal of wastes associated with cooking or preparing food. Equipment that typically utilizes the plumbing system for waste disposal include, but are not limited to tilt skillets, tilt kettles, brazing pans, rotisserie ovens, and Chinese stoves (woks)	Manning's Equation
Equipment Cleaning Fixtures	Equipment cleaning fixtures are those apparatuses that are utilized for the rinsing and cleaning of equipment associated with cooking or preparing food. Equipment cleaning fixtures may include, but are not limited to can washes, mop sinks, automated hood cleaning systems, and washing stations. Enter the maximum water discharge for the equipment cleaning fixture	Faucet Flow
Waste Food Disposal	Enter the peak discharge rate of the waste food grinder, garbage disposal, pulper, etc. per the manufacturer specifications.	Faucet Flow
Washable Kitchen Floor Area	Washable floor areas include all drains located in food preparation and serving areas. The washable floor area contributions toward the grease interceptor flow rate are based on the maximum water supply discharge rate(s).	Faucet Flow

3.1.1 General Equations

When considering a sink draining from a filled initial state, the use of Manning's Equation (3.1) provides an approach to assess the magnitude of flow expected from such a fixture.

$$Q(\text{gpm}) = 669 \frac{AR^{2/3}S^{1/2}}{n} \quad (3.1)$$

where,

$$R = \frac{P_w}{A} \quad (3.2)$$

In Equation 3.1 and Equation 3.2, Q is the flow rate given in gallons per minute, A is the flow area within the pipe (in^2), R is the hydraulic radius of flow (in), S is the pipe slope, P_w is the wetted perimeter of flow (in), and n is the Manning's coefficient value, which depends on the piping material.

For pipe flow, the calculations of area and wetted perimeter depend on how full the pipe is flowing. Figure 3-1 depicts a partially filled pipe.




Figure 3-1. Diagram of Partially Filled Pipe.

Observation of the geometric equations describing the flow area and wetted perimeter of a partially filled pipe indicate that flow calculations depend on whether the height of fluid in the pipe is below or above the half filled point (Figure 3-2).




Figure 3-2. Definition of Variables for Calculation of Area and Wetted Perimeter of Partially Filled Pipes.

Table 3-2 details the equations required for the calculation of the flow area and wetted perimeter for partially filled pipes.

Table 3-2. Summary of Calculations for Partially Filled Pipes Shown in Figures 3-1 and 3-2.

Variable	(A) $d \geq r$	(B) $d < r$
h	d	$2r - d$
θ	$2 \arccos\left(\frac{r-h}{r}\right)$	$2 \arccos\left(\frac{r-h}{r}\right)$
K	$\frac{r^2(\theta - \sin \theta)}{2}$	$\frac{r^2(\theta - \sin \theta)}{2}$
s (arc length)	$r \times \theta$	$r \times \theta$
A (Flow Area)	K	$\pi r^2 - K$
P_w (Wetted Perimeter)	s	$2\pi r - s$

If the equations in Table 3-2 are combined with Manning's Equation (Equation 3.1) with a given slope and 'n' coefficient and plotted for a variety of pipe fill fractions (d/D), the resulting flow rate in Figure 3-3 as a function of the pipe filled fraction would develop.




Figure 3-3. Manning's Equation Flow vs. Fraction Filled.

Figure 3-3 displays a flow rate comparison of 1.5" and 2.5" diameter PVC pipe at a slope of 0.0208, which is the slope required by this North Carolina state regulatory agency. As would be expected, the flow rates under these conditions are substantially different. The implication of this graph is that a 1.5" pipe will never exceed approximately 16 gpm under gravity flow, at the slope and pipe material described. Alternatively, with a 2.5" diameter pipe, the peak flow would be substantially greater (>60gpm).

Under the condition where a filled sink is draining, the use of the Manning's Equation, applied under a conservative filled fraction (~90%) allows for an estimate of the potential flow. When combined with the information regarding approximate sink dimensions, a conservative

and yet appropriate description of flow contribution from a draining sink can be attained (i.e. a flow greater than the sink volume should not be allowed).

In summary, the contributions of the kitchen fixtures to the total flow observed into a grease interceptor are complex. The proposed flow contribution methodology employs the use of common practices and kitchen plumbing in order to quantify a total flow into the grease interceptor.

Fixtures within a kitchen are broken into two primary categories: drained sink fixtures and faucet flow fixtures. The large bursts of flow into an interceptor are likely to come from the draining of sinks and cooking equipment in the kitchen, while the sustained, lower flow rate may come from fixtures that never achieve a filled sink. Figure 3-4 summarizes these statements in a graphical representation.




Figure 3-4. Graphic of Flow Contribution from Various Sink Fixtures.

3.1.2 Calculation of Maximum Flow Rate

The calculation of the maximum flow rate from a FSE kitchen is one of the key parameters for sizing an interceptor. The use of drainage fixture units (DFUs), as proposed by the 2006 UPC, is a common term for plumbers, but is often uncommon to pretreatment coordinators and officials dealing with the regulation of GIs. In addition, the DFU, though reported to take into account the magnitude and frequency of flow, does not differentiate

between a fixture flow and a drained sink flow. Of utmost importance, perhaps, for the regulation of GIs, is the development of a transparent, readily adaptable approach to quantify flow into a GI. Transparency is important so that FSE owners and regulators are aware of the assumptions behind the flow calculations. Adaptability is also important so that future knowledge can be incorporated into the flow calculations as needed.

As stated above, the flow calculations for an FSE GI depend on the number and type of fixtures present in a kitchen. An attached spreadsheet, developed with the Town of Cary, North Carolina, allows for input of the various fixture types, sizes, and characteristics for the calculation of the maximum flow rate into a GI. As a demonstration of the spreadsheets capabilities, a description of an FSE is given in Table 3-3 with the associated inputs to the spreadsheet (Figures 3-5 to 3-7) to compute the flow.

Table 3-3. Summary of Sample FSE for Calculation of Maximum Flow.

Fixture Type	Dimensions	Pipe Diameter (or Fixture Flow)
3 Compartment Wash Sink	3 x 24x24x10	2.0"
2 Compartment Vegetable Prep Sink	2 x 24x24x10	2.5gpm
Pre Rinse Sink	20x20x5	2.5gpm
Dish Machine	-	5gpm
Tilt Kettle	30x24x14	1.5"
Mop Sink	36x36x6	5gpm

The data from Table 3-3 can easily be input into a spreadsheet embedded with the appropriate characterizations and equations for each fixture type. Such a spreadsheet is available with this report as well as at the Town of Cary website. The beginning of the spreadsheet features a section for data input regarding the FSE name and contact information, in conjunction with any added user notes (Figure 3-5).

Project Name:	Full Fare #1
Project Address:	
Project Permit # (if applicable):	xxx
Date Grease Interceptor Sized:	xxx
Grease Interceptor Sized by:	xxx
Company Sizing Grease Interceptor:	xxx
Contact Phone:	xxx
Contact E-Mail:	
General Project Comments:	Demo for WERF Report

Figure 3-5. Contact Information and FSE Input at the Top of the Spreadsheet.

Following this basic description input, the user is presented with the “Ware Washing Fixtures” section of the spreadsheet (Figure 3-6). In this section, the user inputs all the ware washing sinks and their dimensions. The sink drain size is also required in this section. At the top right side of this section, the user can see a small table describing pipe roughness, pipe slope, and maximum flow depth. These values are set automatically for common pipe slopes, roughness coefficients, and a conservative estimate of the maximum flow depth in the pipe. The values can all be modified as needed. The embedded equations within the spreadsheet then make the appropriate Manning’s Equation calculations for this fixture.

Ware Washing Fixtures				
			Pipe Roughness Coefficient	0.008
			Pipe Slope (ft/ft)	0.0208
			Pipe Max. Flow Depth (in)	1.75
Fixture Name #1:	3 Compartment Wash Sink			
	Length (inches)	Width (inches)	Depth (inches)	Sink Drain Size (inches)
Bowl #1	24	24	10	2.00
Bowl #2	24	24	10	Pipe Material
Bowl #3	24	24	10	PVC
Fixture Name #2:				
	Length (inches)	Width (inches)	Depth (inches)	Sink Drain Size (inches)
Bowl #1				
Bowl #2				Pipe Material
Bowl #3				PVC
Fixture Name #3:				
	Length (inches)	Width (inches)	Depth (inches)	Sink Drain Size (inches)
Bowl #1				
Bowl #2				Pipe Material
Bowl #3				PVC
Fixture Name #4:				
	Length (inches)	Width (inches)	Depth (inches)	Sink Drain Size (inches)
Bowl #1				
Bowl #2				Pipe Material
Bowl #3				PVC

Figure 3-6. Data Input for Ware Washing Fixtures.

Food Preparation Fixtures				
				Enter Average Water Supply Pressure (psi) = 80
Fixture Name #1:	2 Compartment Vegetable Prep Sink			
	Length (Inches)	Width (Inches)	Depth (Inches)	
Bowl #1	24	24	10	Max. Faucet Discharge @ 80 psi 2.50 gpm
Bowl #2	24	24	10	
Bowl #3				
Fixture Name #2:				
	Length (Inches)	Width (Inches)	Depth (Inches)	
Bowl #1				Max. Faucet Discharge @ 80 psi gpm
Bowl #2				
Bowl #3				
Fixture Name #3:				
	Length (Inches)	Width (Inches)	Depth (Inches)	
Bowl #1				Max. Faucet Discharge @ 80 psi gpm
Bowl #2				
Bowl #3				
Fixture Name #4:				
	Length (Inches)	Width (Inches)	Depth (Inches)	
Bowl #1				Max. Faucet Discharge @ 80 psi gpm
Bowl #2				
Bowl #3				

Figure 3-7. Food Preparation Fixture Input Section.

As an example of a faucet-flow fixture, the food preparation sink input section (Figure 3-7) displays the required inputs for this section. The user inputs the sink dimensions and the faucet discharge. This discharge and the pressure at the faucet (top right corner) is a readily available number from the plumbing association.

Figures 3-6 and 3-7 display examples of the two types of fixtures present at an FSE. The magnitude of the flow rate may, of course, change depending on the site specific conditions. However, the process described above is the same. The current version of the spreadsheet includes input regions for all the fixtures described in Table 3-1. After this data is input, the bottom of the spreadsheet features a summary table describing the flow contribution from each of the fixtures and the total maximum flow expected from the FSE (Figure 3-8).

As can be seen from the bottom of Figure 3-8, the maximum potential flow from this FSE is 62.10 gallons per minute. This value is an estimate of the worst case scenario flow from an FSE, when all fixtures are running and all sinks are draining simultaneously. Clearly, this is an unlikely scenario. The project team's investigation into the flow observed from FSEs seems to confirm this unlikely scenario. In fact, the FSE described above was monitored during the hours of operation and is displayed in Figure 3-9.

In Figure 3-9, the peak flow shown for the day observed is approximately 21 gpm, far less than the maximum flow rate calculated with the spreadsheet. If a 62 gpm flow rate was utilized for the design flow, it would result in a GI of approximately 2000 gallons at a 30 minute retention time. As a result, a modification is necessary to develop a feasible design flow coming into an interceptor.

Observation of the behavior of several field GIs indicated that approximately one-third of the maximum flow rate would be an appropriate fraction for a design flow rate (companion report 03CTS16TA, *Assessment of Grease Interceptor Performance*). This value appears to be appropriate for the bulk of the fluid passing through the interceptor while handling the likely peak flow rates. For the example full-fare restaurant described above, a design flow rate of approximately 21 gpm would be determined using Equation 3.3.

$$\text{Design Flow (gpm)} = \frac{1}{3} Q_{\max} \quad (3.3)$$

Grease Interceptor Sizing - Plan Review Fixture Summary

Ware Wash Fixture Name	# Compartments	Drain Size/Material	Flow Rate (gpm)
3 Compartment Wash Sink	3	2 in. PVC	31.69
Ware Washing Fixture Flow =>			31.69

Preparation Sink Fixture Name	# Compartments	Flow Rate (gpm)
2 Compartment Vegetable Prep Sink	2	2.50
Food Prep Fixture Flow =>		2.50

Prerinse Name	# Compartments	Flow Rate (gpm)
Pre Rinse Sink	1	2.50
Pre-Rinse Flow =>		2.50

Dishwasher Name	Flow Rate (gpm)	
Dish Machine	5.00	
Dish Washer Flow =>		5.00

Cooking Equipment Name	Drain Size/Material	Flow Rate (gpm)
Tilt Kettle	1.5 in. PVC	15.41
Cooking Equip. Fixture Count =>		15.41

Equipment Cleaning Name	Flow Rate (gpm)	
Mop Sink	5.00	
Equip. Cleaning Fixture Count =>		5.00

Waste Food Disposal Name	Flow Rate (gpm)	
Waste Food Disposal Count =>		0.00

Washable Floor Area Name	Surface Area (ft ²)	Flow Rate (gpm)
Washable Floor Area Flow =>		0.00

Enter Peak Hydraulic Loading Time =>	30	Minutes
Enter Grease Interceptor % Efficiency =>	100%	(% Efficiency)
Enter Grease/Food Solids Storage Factor =>	25%	(% capacity)
Food Waste Disposal Solids Storage =>		(% capacity increase)

Maximum Total Fixture Flow Rate to Grease Interceptor
 gpm

Figure 3-8. Summary of All Fixtures and Flow Contribution.




Figure 3-9. Flow Data Collected Over Operational Hours at Full-Fare FSE.

3.1.2 Maximum Flow Rate Table

Table 3-4 was developed to provide a simplified alternative approach to quantify the maximum flow-rate into a GI without the need to use the GI design spreadsheet.

Table 3-4. Maximum Flow Rate Table.

i	Fixture Type	Fixture Flows		
		1.5"	2.0"	2.5"
A	Ware Washing Fixtures	15	30	60
B	Food Preparation Fixtures	2.5		
C	Pre-Rinse Fixtures	2.5		
D	Dish Washer Units	5		
E	Cooking Equipment	15	30	60
F	Equipment Cleaning Fixtures	5		
G	Waste Food Disposal	2.5		
H	Washable Kitchen Floor Area	5		

In conjunction with Table 3-4, Equation 3.4 could then be applied for the calculation of the maximum flow rate from an FSE.

$$Q_{\max} = \sum_{i=A}^H Q_i n_i \quad (3.4)$$

In Equation 3.4, Q_i represents the flow contribution of a given fixture type and n_i represents the number of fixtures within each fixture type. The maximum flow rate is then determined by the summation of all the flow fixtures multiplied by the quantity of each fixture. This flow rate value will likely be conservative (i.e., produce a larger maximum flow rate) as it does not take into account site specific sink sizes for Manning's Equation calculations or site specific pipe roughness or slope. The assumptions used to make Table 3-4 include: the peak fixture flow rates described for the faucet-flow fixtures, the use of 0.0208 for the value of the slope (S) in Manning's Equation, and the use of the new PVC value for Manning's 'n' (0.008).

In the example shown in Table 3-3, the use of the summary Table 3-4 would indicate the following:

$$Q_{\max} = 30(1) + 2.5(1) + 2.5(1) + 5(1) + 15(1) + 5 = 60\text{gpm}$$

For the example given, the summary table happens to be approximately the same size as the spreadsheet utilized. This similar result is, of course, due to the table flow values coming from the same slope and pipe roughness values currently used in the spreadsheet. However, if the slope for the site specific food service establishment was 0.04 instead of 0.0208 as used in Table 3-4, then the computed max flow would be 81 gpm based on inputting the data into the spreadsheet and be under predicted using Table 3-4 since it would still predict a max flow of 60 gpm. The user should be aware of the assumptions of Table 3-4 before readily using it to compute the FSE flowrate for their specific location. The spreadsheet should be used if the site specific FSE are not consistent with the assumptions listed for Table 3-4.

3.2 Grease Interceptor Sizing

As mentioned earlier, grease interceptors are simple gravity separators that are impacted by the quantity and type of material that is being separated, the hydraulic behavior of the interceptor, cleanout cycle of the grease interceptor, and the operational conditions of the food service establishment. While the hydraulic behavior and quantity and type of FOG were previously discussed, no information was provided on how to compute the necessary size of the grease interceptor based on the operational needs of the food service establishment. Current methods used to assess grease interceptor size based on the food service establishments operating conditions include the following:

Environmental Protection Agency

$$\text{Size (Gallons)} = (\# \text{ seats}) \left(\frac{\text{gallons}}{\text{meal}} \right) (\text{loading factor}) (\text{storage factor}) \left(\frac{\text{hours open}}{2} \right)$$

where gallons per meal is a constant set equal to 5, storage factor equals 1.7, hours open equals 8, and loading factor equals 1.0.

Uniform Plumbing Code (2004):

$$\text{Size (Gallons)} = (\# \text{seats})(\text{flowrate})(\text{hydraulic retention time})(\text{storage factor})$$

where flow rate is equal to 6 gallons per hr and includes the dishwasher flow, the hydraulic retention time is 2.5 hrs, and storage factor equal to 2.0 if the FSE is operated for 16 hours. The revised UPC (2006) computation utilizes an elaborate calculation involving DFUs as described in a previous section and cannot be calculated with a simple relationship as shown above.

Other relationships exist in the literature that are specific to individual municipalities and include more or less similar terms as those used by the UPC (2004) or U.S. EPA equations above. These approaches have been previously criticized in this report since they do not account for the uniqueness in the grease interceptor design. Moreover, they will likely oversize the grease interceptor, which could lead to undesirable conditions such as odors from biological activity in regions that have remain anaerobic too long between cleanout cycles.

As shown in the companion report 03CTS16A, *Assessment of Grease Interceptor Performance*, a large percentage (over 65%) of the field grease interceptors operate with a minimum one hour hydraulic retention time (based on peak flow) with 100% operating at a minimum 30 minutes hydraulic retention time. The flow data in this companion report reveals that only 1% of the total time the food service establishment discharge FOG and solids into the grease interceptor occurs at the maximum flow. When the hydraulic retention time was recalculated using the 90% mark from the cumulative distribution (see Figure 1-2 in *Assessment of Grease Interceptor Performance*), 100% of the grease interceptors operated at a minimum hydraulic retention time of one hour with a majority of those food service establishments (80%) having retention times of two hours. The results in Figure 1-2 of *Assessment of Grease Interceptor Performance* show that the flow representing the 90% mark on the cumulative distribution function is typically 1/3 of the maximum flow rate.

The laboratory results of this study show that tripling the retention time from 20 minutes to one hour only resulted in a 10% increase in the removal of FOG. Further, geometric modifications to the inlet and outlet resulted in similar improvements to removal efficiency at the 20 minutes residence time operation compared with the 60 minutes residence time results. Consequently, it is the project team's recommendation that a 30 minutes residence time, with the geometric configurations discussed in the previous section, represents a reasonable balance between grease interceptors that can operate at 90% removal efficiency while minimizing the chance for development of odors due to anaerobic microbial activity between cleanout periods.

The relationships developed by UPC and the U.S. EPA were not only to account for the hydraulic loading into the grease interceptor but also account for the FOG and solids loading. Work from a previous study (unpublished) has shown that individual plates, utensils, and serving items (i.e., trays, pans, etc.) can generate 3-5 grams of FOG per person served that would be washed down into the grease interceptor. If the maximum FOG amount (5 g/person) is used for a

full-fare restaurant serving 500 persons per hour during peak time, then approximately 2.5 kg per hour would be received by the grease interceptor. During this same period, a large full fare restaurant will likely produce a maximum flow of 45 gpm of water from cleanup and dishwashing.

Based on a 30 minute proposed residence time and a 45 gpm peak flow rate, the minimum volume required is 450 gallons. (Note that the peak flow rate was multiplied by 1/3 to represent the 90% flow rate value on the cumulative distribution function (companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*.) The required storage space for FOG based on the 2.5 kg/hr loading rate is 120 gallons. This value assumes 12 hours of peak operation per day, 15 days between clean out cycles, and 90% FOG removal. It should be noted that the required volume for FOG separation in this example assumes that the FOG characteristics are in the free globule size range (i.e., globule sizes that are larger than 150 microns) for effective gravity separation. The amount of solids that accumulates at the bottom of the grease interceptor will also require space. Food solids analyzed in *Assessment of Grease Interceptor Performance*, displayed very high settling rates, suggesting that the typical empirical relationships for sludge volume index (SVI) may not be used. The computation of the SVI was performed based on first principles as follows:

Stokes particle settling:

$$v_s = \frac{(\rho_p - \rho_f)gd_p^2}{18\mu} \quad (3.5)$$

$$SVI = \frac{\text{dry weight of suspended solids}}{\text{wet solids volume}} = \frac{1}{(\rho_p - \rho_f)} \quad (3.6)$$

Substituting 3.5 into 3.6

$$SVI = \frac{gd_p^2}{18\mu v_s} \quad (3.7)$$

The viscosity of the fluid containing the solids was estimated assuming non-spherical particles as (Rao, 1999):

$$\frac{\mu}{\mu_f} = \left(1 - \frac{\phi}{A}\right)^{-2} \quad (3.8)$$

where μ_f is the fluid viscosity, ϕ is the mass fraction, and A is a constant equal to 0.44 for food particles that have aspect ratios (L/D) between 6-8, which Rao (1999) suggests is a good approximation for most food particles. For the food particles identified in the field studies (companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*), the average

SVI value is approximately 0.06 gallons per lb of solids (This value assumes a solids fraction of 0.003 with the particle sizes identified in this companion report. The maximum storage volume needed for a 2 week pumping frequency is 366 gallons. So for the large restaurant example, the total volume required is 1210 gallons (a standard GI size is 1250).

If calculated using either the U.S. EPA or UPC (2004) approach, the GI size would have been 17,000 and 15,000 (UPC 2004) gallons respectively. Using the alternative UPC (2006) requires more information about the items responsible for generating the 45 gpm flow in the food service establishment. In general, utilizing the revised UPC will result in much smaller grease interceptors than its original 2004 approach. Large GIs as recommended by the U.S. EPA guidelines would result in extremely long solids retention time and lead to significant odors due to low dissolved oxygen content from significant microbial activity. Moreover, it is unclear how the revised UPC (2006) determines the contribution of FOG or solids loading into the grease interceptor using DFUs.

In summary, the recommended approach for computing the size of the grease interceptor should be performed using Equation 3.9

$$\text{Size(Gallons)} = \frac{1}{3} Q_{\max} \times (\text{HRT}) + (\text{FOG Storage Volume}) + (\text{Solids Storage Volume}) \quad (3.9)$$

The FOG Storage Volume can be calculated with Equation 3.10, where Y is the duration between cleanouts.

$$\text{FOG Storage Volume} = \left(5 \frac{\text{g}}{\text{seat-hr}} \right) \left(X \frac{\text{operation hrs.}}{\text{day}} \right) (Y \text{ days}) (0.9) (\# \text{seats}) \left(\frac{264 \text{ gal/m}^3}{\text{FOG Density}} \right) \quad (3.10)$$

The Solids Storage Volume is then calculated by Equation 3.10, where A represents an approximate solids concentration.

$$\text{Solids Storage Volume} = (A [\text{ppm}]) \left(\frac{Q_{\max}}{3} \right) \left(X \left[\frac{\text{operation hrs.}}{\text{day}} \right] \right) (Y [\text{days}]) (SVI) \quad (3.11)$$

CHAPTER 4.0

FACTORS EFFECTING GI PERFORMANCE

4.1 Impact of Emulsifiers on Grease Interceptor Performance

Detergents may contain emulsifiers to aid in the removal of FOG from dishware and kitchen utensils. The role of emulsifiers is to stabilize the interfacial surface by reducing the interfacial tension and preventing FOG from coalescing. Although the effectiveness of detergents containing emulsifiers is to enhance the removal of FOG from utensils and dishware, its addition may also reduce the effectiveness of grease interceptors to separate FOG from the liquid stream. The FOG globules generally achieve a smaller maximum diameter when emulsifiers are included since the surface tension of the FOG globules has been reduced. Hinze (1955) has described how a drop will break in isotropic turbulent flow in the inertial subrange as:

$$d_{\max} = C\varepsilon^{2/5} \left(\frac{\sigma}{\rho_c} \right)^{3/5} \quad (4.1)$$

In Equation 4.1, C is an empirical constant, ε is the local energy dissipation rate, σ is the disperse continuous phase surface tension, ρ_c is the continuous phase density. While this relationship does not characterize all types of turbulent breakup of drops, it does demonstrate that any action leading to the reduction of the surface tension may also lead to the reduction of the maximum drop size. The end result would be the reduction of the FOG globule migration velocity and consequently the removal efficiency (companion report, 03CTS16TA, *Assessment of Grease Interceptor Performance*).

Detergents with emulsifiers' detrimental impact on gravity separation type processes suggest that some counteracting procedure should be employed to increase the size of the FOG globules within the grease interceptor. While this study did not investigate the use of demulsifying agents, the results of this study suggest that any compound that leads to the reduction of the influent FOG globule size will significantly reduce the separation performance as shown in *Assessment of Grease Interceptor Performance* and should be avoided. Best management practices recommend that kitchen cleaners should not use detergents with emulsifying agents to reduce their impact on the grease interceptor separation performance (Stoll and Gupta, 1997).

4.2 Impact of High Temperature Washwater on Grease Interceptor Performance

Experimental tests performed with high temperature water flow into the grease interceptor containing cooler bulk temperatures has demonstrated a density up-flow effect due to the lower relative density of the influent stream compared to the grease interceptor bulk temperature. However, the experimental results showed that short term impact of this density up flow was minor on the effluent FOG concentration and over time, the effluent FOG concentration would be similar to previous uniform influent/bulk temperature results. The experimental results showed that mid-baffle wall provided no significant advantage during the occurrence of a density up-flow event.

While the separated FOG layer may be disturbed by this density up-flow event, the location of the effluent pipe towards the bottom of the grease interceptor suggest that this design requirement may be sufficient to reduce its impact of increasing the FOG effluent concentration due to the disturbed separated FOG layer. Consequently, one design requirement that may be essential to grease interceptors to reduce the impact of density up-flow events on the FOG effluent concentration is the overall depth of the grease interceptor and the close proximity of the effluent pipe towards the bottom of the grease interceptor. Currently, the design calls for depth of the effluent pipe is approximately 1/5 of the depth off bottom.

4.3 The Role of Grease Interceptor Maintenance on Performance

As discussed above, the incorporation of food solids and FOG storage capacity into a GI is an important design consideration when sizing a GI. Equations 3.9, 3.10, and 3.11 already account for this consideration. However, without proper maintenance, the effective size of the GI may be reduced substantially. Though explicit evidence of the result of poor maintenance is currently unknown, observation of field GIs, as shown in the companion report, indicates that scouring of food solids and the already separated FOG layer may be a consequence of substantial buildup in a GI.

The research team recommends that care be taken when establishing a GI clean-out frequency. The best practice may be a simplified maturation study of GIs suspected to have substantial FOG or solids loadings. Such a maturation study would involve taking sludge judge samples of the interceptor at various locations between cleanout frequencies. If a marginal change in FOG or solids layer (or a decrease in those layers) is observed, then it should be noted that the interceptor may have reached its capacity for storage and may need a change in pump-out frequency.

CHAPTER 5.0

CONCLUSIONS AND FUTURE WORK

5.1 Conclusions

Establishing a fair and protective GI size and design guide are challenging goals. The aim of this report has been to establish a set of transparent, fact-based guidelines for the design, sizing, and maintenance of grease interceptors. When combined with the report, *Assessment of Grease Interceptor Performance* (03CTS16TA), detailing the field, experimental, and numerical results for GI performance, the reader should be able to clearly see the basis for the guidelines established in this document.

The current research indicates that a non-compartmentalized, open configuration may provide similar and sometimes enhanced FOG separation over certain compartmentalized designs, contrary to previous literature information regarding GI design. Inlet and outlet piping configurations play a major role in influencing design considerations (i.e. whether mid-baffle walls should be included or omitted). In this study, a few GI design configurations have been proposed to provide at least 90% FOG removal in the free globule size range with a residence time of 30 minutes. These design configurations should be used in conjunction with proposed method to determine the GI size for a specific food service establishment.

This report presents an alternative method to compute the GI size. The approach utilizes a spreadsheet that calculates the flow from a FSE kitchen to a GI based on the available plumbing fixtures utilized within the kitchen. The proposed flow calculations employ the use of common practices and kitchen plumbing in order to quantify a total flow into the grease interceptor. FOG and solids loading are also included in the proposed GI sizing approach to account for the additional storage volume required for separated material accumulated between cleanout cycles.

5.2 Future Work

Research into the area of GI design, operation and maintenance is still in its infancy. Future work in this field will have to consider several factors not included in the present study.

- 1) Alternatives to the large, below ground gravity interceptor are being used by restaurants, such as below sink mechanical and passive traps. As this report does not make any claims into the effectiveness of these devices; it is necessary that similar studies be performed in order to determine the effectiveness of these traps for FOG removal.
- 2) Though the present research has provided insight into the nature of FOG deposits, no information is currently available regarding the physical mechanism by which they accumulate and form the hardened pipe blockages. With this knowledge, further research may lead to the specific form of FOG that will need to be removed by grease interceptors.
- 3) Future research needs to include a methodology to characterize the food service establishment waste stream. This detailed characterization would provide better guidance

into the extent of FOG and solids that can be removed within the GI and possibly offer alternative recommendations into improving the GI removal.

- 4) Additional GI field observations need to be performed across different types of food service establishments that have retrofitted the GI based on the recommendations in this report. This additional field data would validate the proposed design configurations and increase the much needed transparency in the entire GI design process.

REFERENCES

"Energy Policy" Title 42, 6295. Section (J). Energy Conservation Standards (ECS) for shower heads and faucets, 1992.

Garza, O.A., 2004, "Food Service Establishment Wastewater Characterization and Management Practice Evaluation," Texas A&M.

Hee, C., Martyn, P.C., and Kremer, J.G., 2006, Removal of Oil and Grease in Oil Processing Wastewaters.

Hinze, J.O., 1955, "Fundamentals of the Hydrodynamic Mechanism of Splitting in Dispersion Processes." *AIChE Journal*, 1(3), 289-295.

IAMPO, 2004, "Uniform Plumbing Code, Appendix H: Recommended Procedures for Design, Construction, and Installation of Commercial Kitchen Grease Interceptors." IAMPO - UPC.2006 UPC.

NPCA, 2007, Design Considerations and Discussion of Large Outdoor Grease Interceptors, National Precast Concrete Association.

PDI, 1998, "Guide to Grease Interceptors: Eliminating the Mystery." The Plumbing and Drainage Institute, South Easton, MA, 12.

Rao, 1999, "Rheology of Fluids and Semisolid foods, principles and applications", Aspen Publishers, Gaithersburg, MD.

Stoll, U. and Gupta, H., 1997, Management Strategies for Oil and Grease Residue, Waste Management & Research, Vol.15, pp. 23-32.

WASTEWATER UTILITY

Alabama

Montgomery Water Works & Sanitary Sewer Board

Alaska

Anchorage Water & Wastewater Utility

Arizona

Glendale, City of, Utilities Department
Mesa, City of
Peoria, City of
Phoenix Water Services Dept.
Pima County Wastewater Management
Safford, City of
Tempe, City of

Arkansas

Little Rock Wastewater Utility

California

Central Contra Costa Sanitary District
Corona, City of
Crestline Sanitation District
Delta Diablo Sanitation District
Dublin San Ramon Services District
East Bay Dischargers Authority
East Bay Municipal Utility District
Eastern Municipal Water District
El Dorado Irrigation District
Fairfield-Suisun Sewer District
Fresno Department of Public Utilities
Inland Empire Utilities Agency
Irvine Ranch Water District
Las Virgenes Municipal Water District
Livermore, City of
Los Angeles, City of
Los Angeles County, Sanitation Districts of
Napa Sanitation District
Orange County Sanitation District
Palo Alto, City of
Riverside, City of
Sacramento Regional County Sanitation District
San Diego Metropolitan Wastewater Department, City of
San Francisco, City & County of
San Jose, City of
Santa Barbara, City of
Santa Cruz, City of
Santa Rosa, City of
South Bayside System Authority
South Coast Water District
South Orange County Wastewater Authority

Stege Sanitary District
Sunnyvale, City of
Union Sanitary District
West Valley Sanitation District

Colorado

Aurora, City of
Boulder, City of
Greeley, City of
Littleton/Englewood Water Pollution Control Plant
Metro Wastewater Reclamation District, Denver

Connecticut

Greater New Haven WPCA
Stamford, City of

District of Columbia

District of Columbia Water & Sewer Authority

Florida

Broward, County of
Fort Lauderdale, City of
Jacksonville Electric Authority (JEA)
Miami-Dade Water & Sewer Authority
Orange County Utilities Department
Reedy Creek Improvement District
Seminole County Environmental Services
St. Petersburg, City of
Tallahassee, City of
Tampa, City of
Toho Water Authority
West Palm Beach, City of

Georgia

Atlanta Department of Watershed Management
Augusta, City of
Clayton County Water Authority
Cobb County Water System
Columbus Water Works
Fulton County
Gwinnett County Department of Public Utilities
Savannah, City of

Hawaii

Honolulu, City & County of

Idaho

Boise, City of

Illinois

Decatur, Sanitary District of
Greater Peoria Sanitary District
Kankakee River Metropolitan Agency
Metropolitan Water Reclamation District of Greater Chicago
Wheaton Sanitary District

Iowa

Ames, City of

Cedar Rapids Wastewater Facility
Des Moines, City of
Iowa City

Kansas

Johnson County Wastewater Unified Government of Wyandotte County/
Kansas City, City of

Kentucky

Louisville & Jefferson County Metropolitan Sewer District
Sanitation District No. 1

Louisiana

Sewerage & Water Board of New Orleans

Maine

Bangor, City of
Portland Water District

Maryland

Anne Arundel County Bureau of Utility Operations
Howard County Bureau of Utilities
Washington Suburban Sanitary Commission

Massachusetts

Boston Water & Sewer Commission
Massachusetts Water Resources Authority (MWRA)
Upper Blackstone Water Pollution Abatement District

Michigan

Ann Arbor, City of
Detroit, City of
Holland Board of Public Works
Saginaw, City of
Wayne County Department of Environment
Wyoming, City of

Minnesota

Rochester, City of
Western Lake Superior Sanitary District

Missouri

Independence, City of
Kansas City Missouri Water Services Department
Little Blue Valley Sewer District
Metropolitan St. Louis Sewer District

Nebraska

Lincoln Public Works and Utilities Department

Nevada

Henderson, City of
Las Vegas, City of
Reno, City of

New Jersey

Bergen County Utilities Authority
Ocean County Utilities Authority

Passaic Valley Sewerage Commissioners

New York

New York City Department of Environmental Protection

North Carolina

Charlotte/Mecklenburg Utilities
Durham, City of
Metropolitan Sewerage District of Buncombe County
Orange Water & Sewer Authority
University of North Carolina, Chapel Hill

Ohio

Akron, City of
Butler County Department of Environmental Services
Columbus, City of
Metropolitan Sewer District of Greater Cincinnati
Montgomery, County of
Northeast Ohio Regional Sewer District
Summit, County of

Oklahoma

Oklahoma City Water & Wastewater Utility Department
Tulsa, City of

Oregon

Albany, City of
Clean Water Services
Eugene, City of
Gresham, City of
Portland, City of
Bureau of Environmental Services
Water Environment Services

Pennsylvania

Hemlock Municipal Sewer Cooperative (HMSC)
Philadelphia, City of
University Area Joint Authority

South Carolina

Charleston Water System
Mount Pleasant Waterworks & Sewer Commission
Spartanburg Water

Tennessee

Cleveland Utilities
Knoxville Utilities Board
Murfreesboro Water & Sewer Department
Nashville Metro Water Services

Texas

Austin, City of
Dallas Water Utilities
Denton, City of
El Paso Water Utilities
Fort Worth, City of
Houston, City of
San Antonio Water System

Trinity River Authority

Utah

Salt Lake City Corporation

Virginia

Alexandria Sanitation Authority

Arlington, County of

Fairfax County

Hampton Roads Sanitation District

Hanover, County of

Henrico, County of

Hopewell Regional Wastewater Treatment Facility

Loudoun Water

Lynchburg Regional WWTP

Prince William County Service Authority

Richmond, City of

Rivanna Water & Sewer Authority

Washington

Everett, City of

King County Department of Natural Resources

Seattle Public Utilities

Sunnyside, Port of

Yakima, City of

Wisconsin

Green Bay Metro Sewerage District

Kenosha Water Utility

Madison Metropolitan Sewerage District

Milwaukee Metropolitan Sewerage District

Racine, City of

Sheboygan Regional Wastewater Treatment

Wausau Water Works

Australia

ACTEW (Ecowise)

South Australian Water Corporation

South East Water Limited

Sydney Water Corporation

Water Corporation of Western Australia

Canada

Edmonton, City of/Edmonton Waste Management Centre of Excellence

Lethbridge, City of

Regina, City of, Saskatchewan

Toronto, City of, Ontario

Winnipeg, City of, Manitoba

New Zealand

Watercare Services Limited

STORMWATER UTILITY

California

Fresno Metropolitan Flood Control District

Los Angeles, City of,

Department of Public Works

Monterey, City of

San Francisco, City & County of

Santa Rosa, City of

Sunnyvale, City of

Colorado

Aurora, City of

Boulder, City of

Florida

Orlando, City of

Georgia

Griffin, City of

Iowa

Cedar Rapids Wastewater Facility

Des Moines, City of

Kansas

Overland Park, City of

Kentucky

Louisville & Jefferson County Metropolitan Sewer District

Maine

Portland Water District

North Carolina

Charlotte, City of, Stormwater Services

Pennsylvania

Philadelphia, City of

Tennessee

Chattanooga Stormwater Management

Texas

Harris County Flood Control District, Texas

Washington

Bellevue Utilities Department

Seattle Public Utilities

STATE

Connecticut Department of Environmental Protection

Kansas Department of Health & Environment

New England Interstate Water Pollution Control Commission (NEIWPCC)

Ohio River Valley Sanitation Commission

Urban Drainage & Flood Control District, CO

CORPORATE

ADS Environmental Services

Advanced Data Mining International

Alan Plummer & Associates

Alpine Technology Inc.

Aqua-Aerobic Systems Inc.

Aquateam-Norwegian Water Technology Centre A/S

ARCADIS

Associated Engineering

Black & Veatch

Blue Water Technologies, Inc.

Boyle Engineering Corporation

Brown & Caldwell

Burgess & Niple, Ltd.

Burns & McDonnell

CABE Associates Inc.

The Cadmus Group

Camp Dresser & McKee Inc.

Carollo Engineers Inc.

Carpenter Environmental Associates Inc.

Carter & Burgess, Inc.

CET Engineering Services

CH2M HILL

CRA Infrastructure & Engineering

CONTECH Stormwater

Solutions

D&B/Guarino Engineers, LLC

Damon S. Williams Associates, LLC

Earth Tech Inc.

Ecovation

EMA Inc.

Environmental Operating Solutions, Inc.

Environ/The ADVENT Group, Inc.

Fay, Spofford, & Thorndike Inc.

Freese & Nichols, Inc.

ftn Associates Inc.

Gannett Fleming Inc.

Garden & Associates, Ltd.

Geosyntec Consultants

GHD

Golder Associates Ltd.

Greeley and Hansen LLC

Hazen & Sawyer, P.C.

HDR Engineering Inc.

HNTB Corporation

Hydromantis Inc.

HydroQual Inc.

Infilco Degremont Inc.

Jacques Whitford NAWA, Inc.

Jason Consultants LLC Inc.

Jordan, Jones, & Goulding Inc.

KCI Technologies Inc.

Kelly & Weaver, P.C.

Kennedy/Jenks Consultants

KMK Consultants

Larry Walker Associates

Limno-Tech Inc.

The Low Impact Development Center Inc.

Malcolm Pirnie Inc.

Material Matters

McKim & Creed

Metcalf & Eddy Inc.

MPR Engineering Corporation, Inc.

MWH

O'Brien & Gere Engineers Inc.

Odor & Corrosion Technology Consultants Inc.

Paradigm Environmental

Technologies, Inc.

Parametrix Inc.

Parsons

Post, Buckley, Schuh & Jernigan

Praxair, Inc.

Ring Industrial Group

RMC Water & Environment

Ross & Associates Ltd.

SAIC

Siemens Water Technologies

The Soap & Detergent Association

Smith & Loveless, Inc.

Stantec Consulting Inc.

Stearns & Wheeler, LLC

Stone Environmental Inc.

Stratus Consulting Inc.

Synagro Technologies Inc.

Tetra Tech Inc.

Trojan Technologies Inc.

Trussell Technologies, Inc.

Uni-Bell PVC Pipe Association

URS Corporation

Westin Engineering Inc.

Weston Solutions Inc.

Woodard & Curran

Zoeller Pump Company

INDUSTRY

American Electric Power

American Water

Anglian Water Services, Ltd.

ChevronTexaco Energy Research & Technology Company

The Coca-Cola Company

Dow Chemical Company

DuPont Company

Eastman Chemical Company

Eli Lilly & Company

Merck & Company Inc.

Procter & Gamble Company

Suez Environment

United Utilities North West (UUNW)

United Water Services LLC

Note: List as of 8/11/08

WERF Board of Directors

Chair

Dennis M. Diemer, P.E.
East Bay Municipal Utility
District

Vice-Chair

Alan H. Vicory, Jr., P.E., DEE
Ohio River Valley Water
Sanitation Commission

Secretary

William J. Bertera
Water Environment
Federation

Treasurer

James M. Tarpy, J.D.
Metro Water Services

Patricia J. Anderson
City of St. Petersburg,
Florida

Mary E. Buzby, Ph.D.
Merck & Company Inc.

Mohamed F. Dahab, Ph.D.
University of Nebraska,
Lincoln

William P. Dee
Malcolm Pirnie, Inc.

Charles N. Haas, Ph.D.
Drexel University

Jerry N. Johnson
District of Columbia Water
& Sewer Authority

Peter J. Ruffier
City of Eugene, Oregon

Jeff Taylor
City of Houston, Texas

R. Rhodes Trussell, Ph.D.
Trussell Technologies Inc.

Rebecca F. West
Spartanburg Water

Joseph E. Zuback
Siemens Water
Technologies Corporation

Executive Director

Glenn Reinhardt

WERF Research Council

Chair

Peter J. Ruffier
City of Eugene, Oregon

Vice-Chair

Karen L. Pallansch
Alexandria Sanitation
Authority

Christine F. Andersen, P.E.
City of Long Beach,
California

John B. Barber, Ph.D.
Eastman Chemical
Company

William L. Cairns, Ph.D.
Trojan Technologies Inc.

Glen T. Daigger, Ph.D.
CH2M HILL

Robbin W. Finch
Boise City Public Works

Ephraim S. King
U.S. EPA

Mary A. Lappin, P.E.
Kansas City, Missouri
Water Services
Department

Keith J. Linn
Northeast Ohio Regional
Sewer District

Brian G. Marengo, P.E.
CH2M HILL

Drew C. McAvoy, Ph.D.
The Procter & Gamble
Company

Steven M. Rogowski, P.E.
Metro Wastewater
Reclamation District
of Denver

Beverley M. Stinson, Ph.D.
Metcalf & Eddy

Susan J. Sullivan
New England Interstate
Water Pollution Control
Commission

Michael W. Sweeney, Ph.D.
EMA Inc.

George Tchobanoglous,
Ph.D.
Tchobanoglous Consulting

WERF Product Order Form

As a benefit of joining the Water Environment Research Foundation, subscribers are entitled to receive one complimentary copy of all final reports and other products. Additional copies are available at cost (usually \$10). To order your complimentary copy of a report, please write "free" in the unit price column. WERF keeps track of all orders. If the charge differs from what is shown here, we will call to confirm the total before processing.

Name		Title		
Organization				
Address				
City	State	Zip Code	Country	
Phone	Fax	Email		

Stock #	Product	Quantity	Unit Price	Total

Method of Payment: (All orders must be prepaid.)

Check or Money Order Enclosed

Visa Mastercard American Express

Account No. _____ Exp. Date _____

Signature _____

Postage & Handling	
VA Residents Add 5% Sales Tax	
Canadian Residents Add 7% GST	
TOTAL	

Shipping & Handling:			
Amount of Order	United States	Canada & Mexico	All Others
Up to but not more than:	Add:	Add:	Add:
\$20.00	\$7.50*	\$9.50	50% of amount
30.00	8.00	9.50	40% of amount
40.00	8.50	9.50	
50.00	9.00	18.00	
60.00	10.00	18.00	
80.00	11.00	18.00	
100.00	13.00	24.00	
150.00	15.00	35.00	
200.00	18.00	40.00	
More than \$200.00	Add 20% of order	Add 20% of order	
*minimum amount for all orders			

To Order (Subscribers Only):

Log on to www.werf.org and click on "Publications."

Phone: (703) 684-2470
 Fax: (703) 299-0742

WERF
 Attn: Subscriber Services
 635 Slaters Lane
 Alexandria, VA 22314-1177

To Order (Non-Subscribers):

Non-subscribers may be able to order WERF publications either through WEF (www.wef.org) or IWAP (www.iwapublishing.com). Visit WERF's website at www.werf.org for details.

Note: Please make checks payable to the Water Environment Research Foundation.



Water Environment Research Foundation

635 Slaters Lane, Suite 300 ■ Alexandria, VA 22314-1177

Phone: 703-684-2470 ■ Fax: 703-299-0742 ■ Email: werf@werf.org

www.werf.org

WERF Stock No. 03CTS16TBRP

Co-published by

IWA Publishing

Alliance House, 12 Caxton Street

London SW1H 0QS

United Kingdom

Phone: +44 (0)20 7654 5500

Fax: +44 (0)20 7654 5555

Email: publications@iwap.co.uk

Web: www.iwapublishing.com

IWAP ISBN: 978-1-84339-527-0/1-84339527-4



Oct 08